



STATE OF DELAWARE  
OFFICE OF THE STATE FIRE MARSHAL

GROVER P. INGLE  
STATE FIRE MARSHAL

SUSSEX COUNTY  
DIVISION

May 21, 2019

Ms. Donna Nickerson  
Secretary  
Public Service Commission  
861 Silver Lake Blvd  
Cannon Building Suite 100  
Dover DE 19904

RE: CPCN 19-0323 FENWICK 78.00, FRANKFORD 15.00, & OMAR 3.01

Dear Ms Nickerson:

This Agency has no outstanding issues indicating that the applicant has been unwilling or unable to provide safe, adequate, and reliable drinking water service to existing customers.

Where the properties are part of a subdivision, the water system shall be expanded to cover the subdivision. Therefore, fire protection (fire hydrants) shall be install in the entire subdivision(s).

Artesian Water Company, Inc. is aware that they must comply with the Delaware State Fire Prevention Regulations, specifically Regulation 702, Chapter 6, Standard for Fire Flow for Fire Protection, and Regulation 702, Chapter 7, Minimum Requirements for Water Suppliers.

NOTE: According to the Delaware State Fire Prevention Regulation, Regulation 702, Chapter 7, Section 7-1.3.1 the Regulation applies "to all water suppliers, be they public, private, corporations, companies, or individual(s) when providing water for any occupancy, development, or sub-division; and shall apply when extending or improving their franchise districts, their coverage areas, their distribution, transmission or supply infrastructure, and any modifications to their water systems".

Please feel free to contact me if you have additional questions or comments.

Sincerely,



Duane T. Fox, Jr.  
Assistant Chief of Technical Services

dtf/slg

Cc: Artesian Water Company, Inc 664 Churchman's Rd Newark DE 19702